





Edward "Ed" Lethert








Ed Lethert







Electric Shock Drowning Awareness Initiative



Edward "Ed" Lethert Electric Shock Drowning Safety Specialist



Member of the Electric Shock Drowning Prevention Association





Very Honorable mention... PDC Dale Perry

PDC Alan Wentworth

PDC Thad Smyczek





Questions are welcome





James D. Shafer Acredited Marine Surveyor

Began investigating marine leakage currents in 1999


08/16/2018

Ed Lethert

10000 00000








IAEI NEWS July-August 2007

Ed Lethert







Ed Lethert






What is ESD?





ESD is a unique form of drowning caused by the presence of AC electrical currents in freshwater lakes, rivers, swimming pools, ponds, canals, etc.

The current can flow through the body of a living being immersed in the electrically charged water





The current, where sufficiently intense, can paralyze the body's skeletal muscles, inhibiting the ability to swim or move one's limbs (i.e. electrically induced cramp)

The outcome in many such cases is the drowning death of an otherwise healthy individual





Research has determined that an AC current of just **10 mA** passing through the human body is sufficient to cause muscular paralysis and is considered by the ESDPA and others as the threshold for a possible ESD incident

That's two percent of the current flowing through a 60 watt light bulb





Depending on magnitude and path, thru-body alternating current can:

- 1. Paralyze skeletal muscles
- 2. Cause respiratory paralysis (shut down the lungs)
- 3. Initiate ventricular fibrillation
- 4. Cause full cardiac arrest (electrocution)



Table II. Quantitative effects of electric

current on man.

	Milliamperes					
	Direct Current		Alternating Current			
			60	-Cycle	Cycl	es
Effect	Men	Women	Men	Wome	n Men	Women
Slight sensation on hand	1	0.6	0.4	0.3	7	5
Perception threshold, median	5.2	3.5	1.1	0.7	12	8
Shock- not painful and						
muscular control not lost	9	6	1.8	1.2	17	11
Painful shock- muscular						
control lost by 1/2 %	62	41	9	6	55	37
Painful shock - let-go						
threshold, median	76	51	16	10.5	75	
Painful and severe shock-						
breathing difficult, muscular						
control lost by 99 1/2%	90	60	23	15	94	63
Possible ventricular fib-						
rillation						
Three-second shocks	500	500	100	100		

Ed Lethert

10





ESD is a Fresh Water Phenomenon

Fresh Water	0.3 Amp	23.8 mA
Salt Water	6 Amps	1.1 mA
	Leakage <u>Current</u>	Body <u>Current</u>
	In-Water	Through-

Note: 1/20th of the saltwater leakage current results in more than 20 times the body current





Animals are not immune to the effects of electrical currents





ESD has claimed numerous family pets and

Family members, relatives, and others have become victims when entering the water to attempt a rescue





A Terrible ESD Tragedy in 2012

Blackfoot, Idaho







A victim in electrically charged water ...

- May become partially or totally disabled
- May or may not call for help
- May or may not remain conscious
- May or may not remain on the surface
- May make their situation worse while seeking a 'safe haven' by moving toward the source of the current, rather than away from it





Electric Shock Drowning is not the same as death by electrocution, which usually results from direct contact with energized metal objects or surfaces

In-water electrocutions are included in the ESDPA's statistics because they are caused by the same electrical conditions that cause an ESD fatality





What Causes the Shock Hazard?







<u>Two</u> conditions must exist to produce dangerous levels of electrical current in the water...



<u>**1st</u>** — there must be some form of electrical fault (hot to ground) at some point in the AC system or AC powered equipment (on the boat or on the dock)</u>


<u>**2nd</u>** — There must be a failure or loss of the equipment grounding conductor (on the boat or on the dock)</u>






When these conditions exist, significant leakage current (i.e. ground current) is likely to be flowing through the nearby water seeking paths back to the source






10













10



























3. ELECTRICAL FAULT + SAFETY GROUND FAULT = DANGER!












Factors that affect voltage gradients







	In-Water Leakage <u>Current</u>	Through- Body <u>Current</u>
Fresh Water	0.3 Amp (300 mA)	23.8 mA
Fresh Water	0.1 Amp (100 mA)	7.9 mA
Fresh Water	0.03 Amp (30 mA)	2.4 mA



The ESD condition in marinas can be caused by faulty equipment or wiring in or on ...

- The marina/dock electrical system
- One or more boat electrical systems
- Electrically operated boat lifts
- Dock lighting
- Other marina equipment





Similar conditions can exist or occur at private docks where electric equipment and wiring are installed or used

"There are way too many extension cords in use as semi-permanent wiring on private docks" — NEC 400.12 anyone??





An ESD condition in the water is often the result of a low-level fault current that is too small to trip the circuit breaker

These undetected faults can continue for lengthy periods of time, even indefinitely, without any indication or warning of the potential danger

— unless GFCI or GFPE protection is installed —





Worth Noting...

Ground currents associated with electric power transmission can also produce voltage gradients in the water. Such is the case at the Minnetonka Power Squadron Big Island recreation facilty.







Lost to ESD






























Lost to ESD















Lost to ESD

April 16, 2016

Carmen Johnson 15-year-old girl drowns at Smith Lake, Alabama

Coroner: Electrocution may have caused Priceville cheerleader's drowning, along with a 2nd injury and 2 more near-deaths

Family members had earlier reported feeling tingling sensations in the water









Lost to ESD

<u>April 15, 2017</u>

Shelly Darling 34-year-old wife and lawyer dies at Lake Tuscaloosa, Alabama

Elizabeth Whipple 41-year-old wife and lawyer dies at Lake Tuscaloosa, Alabama

















James D. Shafer Capt. David E. Rifkin Quality Marine Services, LLC 2418 Fallen Tree Drive West Jacksonville, FL 32246 904-382-7868 qualitymarinesves@comcast.net

Electric Shock Drowning Incidents – Marinas© (In-Water electrocution fatalities included)

Rev. 10/16/17

Jim Shafer, the originator of this list, is currently unable to participate in this area. Contact David Rifkin for more information.

Low level ground fault leakage in the marina AC shore power system can cause lethal potentials to appear on any underwater metal surface – either on a boat or on the dock. In fresh water the electric field surrounding this surface can paralyze a swimmer. There is no warning that this condition exists, and it has resulted in a number of drownings. Further, there is no post-mortem evidence that electric shock was the cause. Therefore, many of the fatalities listed below are only the <u>known</u> electric shock caused drownings, which were investigated because of circumstantial evidence, i.e., multiple deaths, eye witnesses, considerable distress, cries for help, shock sensation reported by rescuers, etc.

Our studies have shown that, in salt water, the high voltage gradients required for electric shock drowning could not be established with the available fault current levels. In no cases can we attribute cause of death to electric shock drowning in salt water.

We do not know the exact wiring errors or ground faults that created some of the incidents listed below, but it can be assumed that an energized AC conductor (L1 or L2) came in contact with a bonded (grounded) metal object, and coincidently, this object was <u>not</u> connected to the shore bonding (grounding) system. This caused a voltage to appear on these under-water metal objects (both on boats and docks). This created a lethal electric field around the object (a person in this electric field can be paralyzed leading to drowning, or direct electrocution). This was true in every case that was investigated.

No database has been found that catalogs "Electric Shock Drowning" – our term for this phenomenon. The incidents listed below came from various sources, i.e., investigation, press, third party, and eye witness reports. Dates and details are missing for some. There is no way to know what fraction of the total fatalities this listing represents, but it may be reasonable to assume that it could be small. We have no reports of fatalities in salt water due to electric shock drowning.

Some of the fatalities listed here were actually caused by ventricular fibrillation (electrocution), because the victim's head was reported not to have been submerged. They are technically not drownings but are listed here since the causes are similar to drowning by electric shock.

Page 1 of 16

ESD Incident Documentation

as of 01-30-2018

- 99 Known Incidents
- 100+ Known Fatalities
- 58 "Near miss" Incidents







It is believed by many that the actual number of ESD fatalities is much higher than reported or documented, possibly hundreds more

Paralysis resulting from small electric currents passing through the body is generally not recognizable post-mortem as the cause of a drowning





Is ESD a Growing Problem?




- Increase in the use of electrically operated equipment in and around recreational and non-recreational waters
- Increase in Do-It-Yourself electrical work by unqualified and untrained individuals
- Use of non-approved (non-marine grade) materials and equipment, and nonapproved wiring methods on docks and on-board boats





This shore power connector was mis-wired by the owner of the boat, and one result was the ESD death of his wife and daughter



D. Rifkin - J. Shafer

27







Ed Lethert









Older houseboats should be suspect



- Lack of electrical inspections
 [especially recurring / periodic]
- Lack of monitoring for dangerous conditions in and around the water
- Boats connected to shore power system without basic checks to verify correct wiring onboard the vessel











- Postponing of dock or boat repairs due to cost or availability of downtime
- Lack of awareness or understanding of the ESD hazard by the general public







Ed Lethert





 Less caution exercised by the today's general public









Other Areas of Concern...

10













Decorative







08/16/2018

Ed Lethert





Water and Electricity A Dangerous Mix












Cultural Barrier when it's Water + Electricity

Indoors? Be Safe!





Outdoors ???

















10

Use of electric power at docks on lakes and rivers has increased exponentially in recent years. And yet...









Many people are not even remotely aware of Electric Shock Drowning...







... or the need for important precautions Question to Lakeshore Property Owner: "Is the circuit that powers your electrically operated boat lift protected by a Ground Fault Circuit Interrupter?"

Response:

"I have no idea."

The NEC has required GFCI protection outdoors since $\underline{1971}$, in boathouses since $\underline{1987}$, and for boat hoists since $\underline{2005}$









Battery Powered Boat Lift w/ Solar Charger





Signs That There Is -- or Could Be --A Serious Problem




























































The National Electrical Code and ESD



Article 555 — Marinas, Boatyards, and Commercial and Noncommerical Docking Facilities

- Marinas and Boatyards have been addressed in Article 555 of the NEC since 1968.
- 1968 Boat Harbor Wiring
- 1971 Marinas and Boatyards (and residential docks)
- 2002 Marinas and Boatyards (exempted residential docks)
- 2017 Marinas, Boatyards, and Commercial and Noncommercial Docking Facilities




10






What Articles of the NEC apply to ESD?

- Article 555 Marinas, Boatyards, and Commercial and Noncommercial Docking Facilities
- Article 680 Swimming Pools,
 Fountains, and Similar Installations
- Article 682 Natural and Artificially Made Bodies of Water
- Article 551 Recreational Vehicles and Recreational Vehicle Parks
- Article 553 Floating Buildings
- Article 525 Carnivals, Circuses, Fairs, and Similar Events











Significant Influence on Article 555










Ed Lethert








08/16/2018

Ed Lethert





Typical Dock Electrical Distribution Prior to 2011




No ground-fault protection required for marina main service or for shore power service





Typical Dock Electrical Distribution 2011 and 2014 NEC




555.3 Ground-Fault Protection. The main overcurrent protective device that feeds the marina shall have ground fault protection not exceeding 100 mA. Ground-fault protection of each individual branch or feeder circuit shall be permitted as a suitable alternative.





Typical Dock Electrical Distribution 2011 and 2014 NEC




555.3 Ground-Fault Protection. The main overcurrent protective device that feeds the marina shall have ground fault protection not exceeding 100 mA. Ground-fault protection of each individual branch or feeder circuit shall be permitted as a suitable alternative.





Typical Dock Electrical Distribution 2011 and 2014 NEC




555.3 Ground-Fault Protection. The main overcurrent protective device that feeds the marina shall have ground fault protection not exceeding 100 mA. Ground-fault protection of <u>each individual branch</u> or feeder <u>circuit</u> shall be permitted as a suitable alternative.





On-Board ELCI (30 mA Trip)






Required by ABYC Standard E-11 for AC equipped recreational boats built after December 31, 2012





Typical Dock Electrical Distribution 2011 and 2014 NEC




Equipment Leakage Circuit Interrupter: required by ABYC Standard E-11 for AC equipped recreational boats built after December 31, 2012







Typical Dock Electrical Distribution 2017 NEC



555.3 Ground-Fault Protection. The overcurrent protective devices that supply the marina, boatyards, and commercial and noncommercial docking facilities shall have ground-fault protection not exceeding 30 mA.





Marina Ground Fault Leakage Current and the NEC

Ed Lethert

January 3, 2017

Article 555 of the 2014 National Electrical Code, "Marinas and Boatyards", has been re-titled

in the 2017 edition to "Marinas, Boatyards, and Commercial and Noncommercial Docking Facilities". Along with the new title, there are important changes and additions including a very important revision. The revised rule. Section 555.3, has reduced the maximum permitted ground-Marina Greeco function for 30 mA and apply sub-equilements and additions are the constrained of the constraint of the constraint

555.3 Ground-Fault Protection. The overcurrent protective devices (OCPDs) that supply the marina, butyanis, and commercial non-new protectial docking facilities have a weight of the protection of the protection

"2017 National Electrical Code, ARTICLE 555 — Marinas, Boatyards, and Commercia and Noncommercial Docking Facilities


The 2014 code rule require **Exce** gbuerthere precise the exceeding 100 mA be applied at the main service feeding the marka, an permet precise the exceeding 100 mA be applied at the main service feeding the marka, an permet precise the exceeding 100 mA be applied at the main service feeding the marka, and permet precise the exceeding 100 mA be applied 2017 code rule requires that *ALL* overcurrent protective devices in marinas, boatyards, and at commercial and non-propertied period. The the service of the exceeding 30 mA. Reading further and the exceeding 100 mA be applied at the the the exceeding 30 mA. Reading further and the exceeding 100 mA be applied at the the the the exceeding 30 mA. Reading further and the exceeding 30 marka and dock convenience receptacles. This reduction in the ground-fault trip level was driven in large part by the The Fire Protection Research Foundation. The rationale for their conclusions and list of participants is found in their report *Assessment of Hazardous Voltage/Current in Marinas, Boatyards and Floating Buildings.*²

Anyone involved with marina electrical installations and their operation must consider the potential negative consequences that could result if this new rule is not applied thoughtfully and reasonably in the field, especially as it relates to shore power service to watercraft. It is also important to note that Article 555 makes no distinction between freshwater and saltwater marine environments, even though there are significant differences, electrically speaking.

¹milliamperes



²Assessment of Hazardous Voltage/Current in Marinas, Boatyards and Floating Buildings, Final Report, November 2014, Fire Protection Research Foundation







		Grou	irrent	
Location	Feeders Measured	Feeders Exceeding 30 mA	Feeders Exceeding 100 mA	Feeders Exceeding 1.0 A
Miss Croix Yacht Harbor	6	5	2	0
River Heights Marina	9	9	6	2
Port of Sunnyside Marina	18	12	11	2
Lake City Marina	15	7	6	0
St. Croix Marina	16	15	15	6
Totals	64	48	40	10
Majority of feeders are 12	0/240 Volts	s - 200 Amp	s.	
Measurements averaged o	over 2-3 mii	nutes.		



10

ELECTRICAL CURRENT MEASUREMENTS

FOSS HARBOR MARINA

821 DOCK ST.

TACOMA, WA 98402

LOCATION	# OF SLIPS	FEEDER SIZE	L1 + L2 + L3 + NEUTRAL	L1 + L2 + L3 + NEUTRAL + GROUND	GROUND ONLY	WOULD 100 mA BREAKER TRIP?	WOULD 30 mA BREAKER TRIP?
B-DOCK #1	4	125A	1,510 mA	190 mA	130 mA	YES	YES
B-DOCK #2	4	125A	8,400 mA	400 mA	8,720 mA	YES	YES
B-DOCK #3	5	150A	8,930 mA	1,100 mA	6,470 mA	YES	YES
B-DOCK #4	4	125A	2,600 mA	340 mA	2,430 mA	YES	YES
C-DOCK - ODD	13	100A	1,300 mA	400 mA	1,960 mA	YES	YES
C-DOCK - EVEN	13	100A	540 mA	600 mA	650 mA	YES	YES
D-DOCK - ODD	14	125A	920 mA	2,250 mA	2,000 mA	YES	YES
D-DOCK - EVEN	10	125A	2,600 mA	3,300 mA	1,640 mA	YES	YES
F-DOCK - ODD	14	125A	700 mA	830 mA	650 mA	YES	YES
F-DOCK - EVEN	13	125A	9,800 mA	2,850 mA	7,950 mA	YES	YES
G-DOCK - ODD	12	125A	7,030 mA	1,180 mA	3,820 mA	YES	YES
G-DOCK - EVEN	12	125A	2,320 mA	840 mA	4,950 mA	YES	YES
H-DOCK - ODD	15	125A	0 mA	800 mA	270 mA	NO	NO
H-DOCK - EVEN	15	125A	9,500 mA	3,800 mA	2,900 mA	YES	YES
I-DOCK - ODD	13	125A	120 mA	930 mA	120 mA	YES	YES
I-DOCK - EVEN	13	125A	11,280 mA	1,450 mA	10,200 mA	YES	YES
J-DOCK - ODD	13	125A	350 mA	300 mA	380 mA	YES	YES
J-DOCK - EVEN	13	125A	110 mA	110 mA	590 mA	YES	YES
K-DOCK - ODD	15	125A	160 mA	3,330 mA	3,330 mA	YES	YES
K-DOCK - EVEN	15	125A	6,140 mA	390 mA	6,000 mA	YES	YES
L-DOCK - ODD	15	125A	130 mA	460 mA	230 mA	YES	YES

D.F. ELECTRIC, INC.

12/4/17






ELECTRICAL CURRENT MEASUREMENTS

	FOSS HARBOR N 821 DOCK ST. TACOMA, WA 9840								
Tota	l Feeders		35						
Tota	l Slips		411						
Tota	ls			435	50 1 3	81960	131.960	0	
Aver	ages				3	3770	3.770		
	rage/Slip					321	0.321		
Leak	age:				Fe	eders:			Slips:
> 3	0 mA (0.03 A)				33	(94%)		2	4 (69%)
> 1	00 mA (0.1 A)				33	(94%)		1	8 (51%)
	00 mA (0.5 A)					(69%)			2 (34%)
	.0 A					(54%)			3 (9%)
> 5.	.0 A					(34%)			_
	0.0 A					(5.7%)			-
	K-DOCK - ODD	15	1258	100 1114	5,550 HIA	5,550 HIA	160	165	
	K-DOCK - EVEN	15	125A	6,140 mA	390 mA	6,000 mA	YES	YES	_
	L-DOCK - ODD	15	125A	130 mA	460 mA	230 mA	YES	YES	
	D.F. ELECTRIC, INC.							12/4/	17





Typical Dock Electrical Distribution 2017 NEC




Tentative Interim Agreement 17-15 (*TIA Log #1348*)





Typical Dock Electrical Distribution 2020 NEC (*Proposed*)



555.35 Ground-Fault Protection of Equipment (GFPE) ...

(A) Ground-Fault Protection. ..., ground-fault protection for docking facilities shall be provided in accordance with the following:


(1) Receptacles Providing Shore Power.

Receptacles installed in accordance with 555.19(A) shall have individual GFPE set to open at currents not exceeding 30 milliamperes.





Typical Dock Electrical Distribution 2020 NEC (*Proposed*)



555.35 Ground-Fault Protection of Equipment (GFPE) ...
(A) Ground-Fault Protection. ..., ground-fault protection for docking facilities shall be provided in accordance with the following:

(3) Feeder and Branch Circuit Conductors With GFPE. Feeder and branch circuit conductors that are installed on docking facilities shall be provided with ground-fault protection of equipment (GFPE) set to open at currents not exceeding 100 mA. Coordination ...





Received by Mike Holt on Friday, April 27, 2018 6:17 PM

catalinaislandtime

I just moved into a marina that has GFCI on each shore power connection (10mA protection). IT'S THE WORST!!! This shore power is useless, it so sensitive around a wet environment! I swear, when the fog comes in too dense the damn breaker trips and I lose shore power. My refrigeration goes out and my batteries die. The idiot that came up with this crap thinks he's a saint (saving lives, blah blah blah; sounds like an ego thing to me) I have never heard of a death in any of our (ocean) marinas, we have divers, and all swim in them.





Received by Mike Holt on Friday, April 27, 2018 6:17 PM

Catalinaislandtime (cont'd)

The unintended consequences of damaged marine equipment from shore power cutting out when boat owners are not around is going to get marinas, cities and code writers sued. Just wait, the marine industry is just starting to realize the problems from GFCI shore power, lawsuits are looming on the horizon. This new code has made shore power completely unreliable.





Reactions to the 2017 NEC



National Electrical Code





Department of Labor and Workforce Development Labor Standards and Safety

Post Office Box 111149

Juneau, Alaska 99811 Main: 907.465.4855 Fax: 907.465.6012

April 21, 2017

The Honorable Representative Sam Kito III Alaska House of Representatives 120 Fourth Street, Room 403 Juneau, AK 99801

Dear Representative Kito,

This letter is in response to concerns received by your office about a provision in the upcoming 2017 edition of the National Electrical Code. An erroneous interpretation of this code would create an unrealistic requirement for dock, marina, and boatyard owners. The Department of Labor and Workforce Development interprets the National Electrical Code according to the developers' intent, and hopes to allay any concerns that it might do otherwise.

Under AS 18.60.580, the National Electrical Code (NEC), developed and published by the National Fire Protection Association (NFPA), constitutes the minimum electrical safety standards of the state, applying to new installations and alterations to existing installations. The Alaska Department of Labor and Workforce Development may adopt the most recent version by regulation. The department may only adopt amendments issued by the American National Standards Institute, the body that approves the NEC. Any other amendments must be made in Alaska statute.

The department updates to a new NEC edition on a three-year cycle. The 2014 edition is the current version adopted in 8 AAC 70.025. The process of adopting the 2017 edition will begin in the spring of 2018, with an expected effective date near the end of 2018. This timeframe allows public and industry analysis of the new version, with ample time for legislation if amendments are necessary to adapt the code to Alaska's environment.

Several local organizations have expressed concern about a provision of the 2017 edition. Section 555.3 defines ground-fault protection requirements for marinas, boatyards, and commercial and noncommercial docking facilities. It reads:

"555.3 Ground-Fault Protection. The overcurrent protective devices that supply the marina, boatyards, and commercial and noncommercial docking facilities shall have ground-fault protection not exceeding 30 mA."

There is concern that the department may interpret this provision as requiring 30 mA groundfault protection for all overcurrent protective devices in an affected facility, up to and including the main feeder. According to industry representatives, a 30 milliamp protection requirement at f nuisance trips due to the cumulative effect of boatyard.

chnical representatives, the department has the section. Instead, the intent is to require 30 point in the marina. This may be achieved circuits.

ttee that revised Section 555.3 stated in its nit is consistent with that recommend in the Fire ent of Hazardous Voltage/Current in Marinas, teed report is available to the public and guage.² The final sentence of that report tion on main feeder protection, citing the need level may be determined.

w Section 555.3, several organizations a Fine Print Note to Alaska's adoption of the

plied to all feeder circuits or all branch circuits device."

ineer Mark Morris, stated in an October 2016 nge to the National Electrical Code, it is just a ting the code." The department agrees with his nnecessary. Assistance in interpreting the code The NFPA offers its members one-on-one help sources available from private code consultants, ctors provide assistance when questions arise. certainty in this matter, Mechanical Inspection gnize and clarify misconceptions surrounding

National Electrical Code for the State, the t of Labor and Workforce Development will code according to the intent of the National Fire enforce an erroneous interpretation requiring 30

)_A2016_NEC-P19_FD_ballotfinal.pdf, p. 81 resources/research-foundation/research-foundationtinmarinasboatyardsandfloatingbuildings.pdf?la=en ipa-technical-auestions t device. We will continue to educate and

nal questions or concerns.

bor and Workforce Development Inspection

hairman, Port of Juneau of Sitka Iarbormasters and Port Administrators



National Electrical Code







December 11, 2017

Mr. Joel Sacks, Director Washington State Department of Labor & Industries P.O. Box 44000 Tumwater, WA 98504-4000

ATTN: Labor & Industries team (Mr. Stephen D. Thornton, Mr. Rod Mutch, Ms. Maggie Leland, Ms. Tammy Fellin)

RE: Proposal asking Labor & Industries to retain, beyond July 1, 2018, the current standard in WAC 296-46B-555(1) and to insert a provision that addresses stray current at the pedestal.

Dear Director Sacks:

Northwest Marine Trade Association (NMTA) and the Recreational Boating Association of Washington (RBAW) are jointly submitting these written comments on the Department of Labor & Industries (L&I) consideration of the National Electrical Code (NEC) as it relates to marinas, boatyards, and commercial and non-commercial docking facilities. This part of the code can be found at Article 555.3 NFPA 70 -2017 NEC, with the State's adoption at WAC 296-46B-555(1).

By way of background, both NMTA and RBAW are national leaders. NMTA recently marked its 70th year of service and is now the nation's oldest and largest regional marine trade association with 725 member businesses and public ports, including 70 marinas and 55 boatyards. As for RBAW, they celebrated their 60th anniversary in 2016. They act as a legislative and regulatory voice for recreational boaters, with 1,300 individual members and about 8,000 more members spread across 50 boating and yacht clubs in Washington.

Both organizations have a proud safety record. Led by former RBAW President Steve Greaves and NMTA volunteer leaders, industry and boaters brought forward the current mandatory boater education law in Washington state. We have long realized that safe boating is fun boating.

With respect to the NEC, please remember that it is not a regulatory document. It is a safety standard that is intended to be suitable for mandatory application by government bodies that exercise legal jurisdiction over electrical installations. This guidance is provided in NEC Section 90.4.

a specific request to L&I that the the feeders does not go far enough. at the feeders and 30mA at the	larine Manufacturers In we can draw for the	ple." To reiterate,
thru June 2018 according WAC 296-	ciding panel lacked	oport a change to communication
thru June 2018 according WAC 298-		f there is a
	Vehicle (RV) industry and	
gue with L&I since this issue first	dard as it applies to marinas.	ITA-RBAW: It is
/larch 2017. We took immediate	lutch himself has stated,	ety proponents,
won a one-year extension of the	tle if the ultimate arbiters	ough standard
		bers are on L&I.
meeting at Elliott Bay Marina on	n that "If it was good enough	in Lon.
t 100mA of stray current plus the	(the NEC code panel)." The	e NASCAR race car
rst, focusing specifically on the	hat happens on a boat, not	oposal is more I that is not based
protection requires a standard below	hed letter or feel free to	eaders of the most
ond, 100mA of stray current on	y about the correct level of	
te a standard that is not sustainably		ck, will almost
ther reinforce this point.	occurred to look at this	rip rating on the
	hat even the number we can	item entirely. After
, who attended both meetings with	stray current in a marine	tinct possibilities. re is inherent
to see what is actually happening on	n a 360-degree field. Even	when there is no
ey compiled his findings in a report,	e does not delineate by our members.	
did: In its existing condition, the	by our members.	ind stakeholders
ed" by a GFI breaker. Interestingly,	v are "practicable".	rom tripping, the
andent work.	nnot be practically	ntially unsafe
asure of stray current into the water.	out from transformers to hot as to the hardship that's	liminate a ground
	tentially making marina	
Association of the Society of	ng upgrades and	the only approach
ociations as they adopt standards at	e Electric Shock Drowning	
gold standard when it comes to best	h L&I.	tional leaders on
	so-called improvements.	
he criteria that constitutes a sound	esentatives who have	
ted code was not "justifiable and	ey even tracking this issue)	
portion of the code was based on an		
eted by the code panel. During one	C 296-46B-555(1) has	
nit a letter sharing the mission of	ry adoption without	
BYC has written that letter (also	he State of Alaska has	ov. Affairs
ear to be any rationale for the leap	he same.	ciatio
	ve already taken steps to	
ders" (as the manual stipulates it	Our change is "explicit"	
eloped in a "broad-based" and an	ctive Device (i.e. circuit	
at represent marinas and marine		
t includes the Association of Marina		
Boat Builders and Repairers		



National Electrical Code



December 15, 2017

Ms. Kerry M. Bell, Chair National Fire Protection Agency Standards Council 1 Batterymarch Park Quincy, MA 02169-7471

Re: AMI Comment submission re Tentative Interim Agreement 1348 (TIA 1348)

Dear Ms. Kerry Bell,

The Association of Marina Industries (AMI) desires to be an industry leader in the area of minimizing the dangers in marinas due to Electric Shock Drowning (ESD). AMI addresses the ground-fault application in marinas as a positive step toward mitigating the effects of ESD. AMI membership also strives to ensure that the language in Federal guidelines such as the National Electric Code (NFPA 70) provides realistic operational and functional parameters in order to manage a safe and efficient marina. At this time, AMI does not agree with the language proposed in TIA 1348(2). This TIA does not address or resolve the shore power electrical system reliability issues marinas will face because of the overly restrictive requirement of Section 555.3 of the 2017 NEC (NFPA 70). While the AMI agrees that ground-fault protection is not essential (and not practicable in most situations) at the marina main service, the requirement for groundfault protection not to exceed 30 mA for the (dock) feeders and branch circuits, along with the potential for problems it poses, is not addressed. Adoption of TIA 1348 will only lend further credence to the belief that ground-fault protection not to exceed 30 mA at the dock feeder OCPD will not be detrimental to reliable system operation. In our opinion, and based on the evidence we have, it could well be very detrimental.

AMI is the largest nationwide membership organization devoted directly to the marina, boatyard and yacht club industry. Of its 1250 members, 885 are marinas, boatyards or yacht clubs. Represented by the organization is 29% of the estimated 35,000 full and part-time employees in the industry and over 300,000 boaters using 164,000 boat slips at AMI member facilities.

Commentary:

There is increasingly broad concern in the marina industry that overly restrictive ground-fault protection requirements for marinas, and specifically for dock wiring, will result in serious operational problems while not significantly improving electrical safety in the marina environment.

There is also a concern that some marina operators will find it necessary to bypass newly required safety provisions and might do so after completion of any electrical inspections. Such actions could create conditions that are even more hazardous.

Also, there is growing evidence that the ground-fault current existing on dock feeder circuits in marinas can be substantial in nature and yet not create conditions in the water that are hazardous to human beings. Data providing expected or actual ground-fault leakage for marina dock feeders is scarce, to say the least. This past summer, a private individual in Minnesota measured the ground-fault current on approximately 64 dock feeder circuits in five Minnesota and Wisconsin marinas, all located on the Mississippi and St. Croix Rivers. Forty-eight of these measured currents were well in excess of 30 mA even 100 mA— and yet no serious voltage gradients were found in the water surrounding boats connected

1

AMI Comment on TIA 1348

December 15, 2017

ained by looping a flexible current fforts as "sobering." The Care was taken to exclude the addressed in ell be unworkable and on the St. Croix River were typical installer sees seek a result that is the 200 ampere feeders serving four p on the OPD iod of a few minutes, the average ers measured below 30 mA. (The tion 555.2 be revised to eder breakers amperes. The next lowest feeder er from using the measurements for the five rogram at this a program like ccess to the water and to on econdary of a otected, these tion 555 3 2017 National ted as the interim 555.3 acles 150V to been added in ound-fault protection for cer to relieve r the docking ound-fault protection not revised NFPA uit shall be permitted as a overlooked in tion at do not exceed 3m (10 ft.) und-fault protection. This nulate specific the transformer secondar the design of ce of hazardous voltage gradients urrent issues. age gradients in the water with a oving forward es installed in accordance Preliminary Shafer and Rifkin point out that derstand ESD, arina" is necessary to hazardous voltage gradients are tion. The Fire vered by Article 555 that d the need to und that 2.2 amperes of current ent of specific provisions the 2017 NEC (ft. (vertical). From that, we can ered within the scope of 555.3 and the the water to produce a voltage installers and case occurred in water having a lication of the l circuit breakers located ptionally low level of conductivity d well bevond the definitions in NFPA av of electrical v higher, and the strength of the 2017 NEC are the waterfront, including on this inverse relationship, the the proposed language, onductivity is hundreds of times mber 15, 2017 g facility, where there is at floating buildings are Washington conducted similar December 15, 2017 are included with this document December 15, 2017





State by State Marina by Marina

More investigation of marina ground currents required

o Now What ?



National Electrical Code



Signage





³ Warning Signs required stating "WARNING - POTENTIAL SHOCK HAZARD -ELECTRICAL CURRENTS MAY BE PRESENT IN THE WATER."

555.24 Signage. Permanent safety signs shall be installed to give notice of electrical shock hazard risks to persons using or swimming near a boat dock or marina and shall comply with all of the following:

(1) The signage shall comply with 110.21(B)(1) and be of sufficient durability to withstand the environment.

(2) The signs shall be clearly visible from all approaches to a marina or boatyard facility.

(3) The signs shall state "WARNING — POTENTIAL SHOCK HAZARD — ELECTRICAL CURRENTS MAY BE PRESENT IN THE WATER." [555.24 is a new section added to the 2017 NEC]







A sign could have made a difference







Electric Shock Drowning Prevention Association



<u>Awareness</u>

Education

Mitigation

Founded on July 15th 2011





03/25/2009

Harbor Cove Marina, Duluth, MN













Electric Shock Drowning Prevention Association



Awareness Education Mitigation

Founded on July 15th 2011





Significant Coverage by Boating and Marina Publications







Increasing Coverage by Media





WCCO-TV CH 4, 10 PM News, June 28, 2016

UK Daily Mail, May 21, 2016







Electric Shock Drowning Prevention Association



Awareness Education Mitigation

Founded on July 15th 2011





Proactive Mitigation is essential to protect

- those in the water unintentionally
- the uninformed (includes animals)
- the misinformed
- the disbelieving
- those careless regarding their wellbeing and the well-being of others
- And even trespassers





Electrical safety goals should include

- ✓ <u>Enforceable</u> safety standards
- ✓ Quality and skilled workmanship
- Inspection by competent authority
- ✓ Mandatory recurring inspection
- ✓ Continuous monitoring?
- ✓ Routine testing and maintenance
- ✓ EDUCATION OF THE PUBLIC



Stricter requirements have been or are being enacted in some states

NFPA® 303

Fire Protection Standard for Marinas and Boatyards

2016 Edition

rymarch Park, Quincy, MA 02169-747 nel Codes and Standards Organizatio

- West Virginia
- Tennesee
- Kentucky
- Missouri
- Arkansas






SHOCK ALERT













When Is It "<u>Safe</u>" to Go Into the Water?





'Safe' is defined in Noah Webster's 1828 Dictionary as

- 1. Free from danger of any kind
- 2. Free from hurt, injury or damage
- 5. Placed beyond the power of doing harm



The term "**safe**" to enter the water can be misleading and should never be used in the context of water safety where electric equipment and wiring are installed

The phrase "<u>degree of risk</u>" would be more suitable and avoids any inference that absolute safety is assured






When is the risk of ESD "very low"?

The Electric Shock Drowning Prevention Association recommends maintaining a minimum distance of <u>150 feet</u> from all AC electrical equipment and wiring


This separation should reduce the risk of an ESD accident to a very low level for any in-the-water recreational and nonrecreational activities






Conditions are always subject to change





Conditions are always subject to change





Conditions are always subject to change





July 4, 2014 Lake of the Ozarks, MO – 7 mi marker

Several people were swimming at a private dock when they started feeling tingles. Turning off the power at the dock did not solve the problem. A contractor found an electrical short at an abandoned boat ramp about 100 yards away. The power was disconnected and the electricity [tingles] in the water ceased.

"Near Miss" Case No. 5





Recommendations



<u>A Proposed Minimum Requirement</u>

All facilities, from the largest marina to the smallest residential dock, should have instructions posted in a conspicuous location that indicate where and how to disconnect the power to all equipment in, on, over, or near the water





A Proposed Minimum Requirement

Marinas should have an emergency response plan and all staff should be familiarized with that plan and trained in proper response procedures

Marinas should familiarize their customers with ESD hazards along with other items of importance







EPO Switch for Marinas and Docks?





Emergency Electrical Disconnects

NEPA Public Input No. 2894-NFPA 70-2017 [New Section after 555.17]

555.16 Emergency Electrical Disconnects. Permanent dock installations, including fixed and floating docks, shall be provided with a clearly identified emergency shutoff device or electrical disconnect at the feeder disconnecting means. Such devices or disconnects shall be installed at or near the feeder disconnecting means and not less than 3 m (10 ft) from the dock that it serves. Emergency shutoff devices or electrical disconnects shall be installed at or near the feeder disconnecting means and not less than 3 m (10 ft) from the dock that it serves. Emergency shutoff devices or electrical disconnects shall be installed at or near the feeder disconnecting means and not less than 3 m (10 ft) from the dock that it serves. Emergency shutoff devices or electrical service to the dock; to all associated shore power, control, and signal circuits; and to all other electrical equipment associated the dock. When more than one emergency shutoff device or electrical disconnect is provided, all devices shall be interconnected. Resetting from an emergency shutoff condition shall require manual intervention and the manner of resetting shall be approved by the authority having jurisdiction.

Statement of Problem and Substantiation for Public Input

A significant number of marina-related deaths and injuries have occurred in recent years that were the direct result of electrical faults and other electrical problems in and around marina facilities. Would-be rescuers have also become victims when entering the water to aid a victim or victims before shore power to boats or other equipment was disconnected. In a great many cases, the location of the disconnecting means is either inaccessible or unknown. A readily accessible and clearly marked disconnecting means similar to that found in fuel dispensing facilities could help to reduced the number of deaths and injuries by increasing awareness of the potential danger and by providing the readily accessible means necessary to disconnect all electrical power to the boats and other electrical equipment.

Submitter Information Verification

Submitter Full Name: Edward Lethert Organization: Ed Lethert Assoc Inc Street Address: City: State: Zip: Submittal Date: Mon Aug 28 17:18:20 EDT 2017

Copyright Assignment

I, Edward Lethert, hereby irrevocably grant and assign to the National Fire Protection Association (NFPA) all and full rights in copyright in this Public Input (including both the Proposed Change and the Statement of Problem and Substantiation). I understand and intend that I acquire no rights, including rights as a joint author, in any publication of the NFPA in which this Public Input in this or another similar or derivative form is used. I hereby warrant that I am the author of this Public Input and that I have full power and authority to enter into this copyright assignment.

By checking this box I affirm that I am Edward Lethert, and I agree to be legally bound by the above Copyright Assignment and the terms and conditions contained therein. I understand and intend that, by checking this box, I am creating an electronic signature that will, upon my submission of this form, have the same legal force and effect as a handwritten signature





"That's a great idea to have an emergency pushbutton at all docks with electricity, ...



Mike Holt, Electrical Trainer, Consultant, Author, Publisher Private communication – 05-30-2016







How about swimming pools?





In Conclusion





Remember & Remind: In-the-water shock hazards can exist—or occur suddenly without notice or warningwherever shore-powered AC electrical equipment is located in, on, over, or near the water!





The ESDPA recommends:

DO NOT enter the water in the vicinity of shore powered watercraft or equipment, for any reason — EVER!

Stay at least <u>150 feet</u> away from all electrical equipment and wiring !





Responding to An Electric Shock Drowning Incident

This is important and useful information for law enforcement officers, firefighters, emergency medical technicians, marina staff, boaters, lake property owners, and the general public.

The combination of humans (or pets), water and electricity can be deadly. An in-the-water shock hazard can exist wherever shore-powered AC electrical equipment is located in the water, over the water, or near the water. See links at bottom of page for additional information.

Typical Electric Shock Drowning Scenario

- · The victim enters electrically charged water (i.e. swims, wades, jumps, paddles or falls).
- · The victim may feel a tingling sensation; or may become partially or totally disabled.
- The victim may or may not remain conscious.
- The victim may or may not remain on the surface.
- · The victim may or may not call for help or make sounds indicating distress (scream, etc.).
- The victim's situation may worsen when seeking a "safe haven." This is likely if they move toward
 rather than away from the source of the electrical current

Recommended Actions for ESD Victims

The victim should, if able, keep their arms and legs close to their body (this action will reduce
exposure to the voltage gradients in the water).

Responding to an ESD incident

- must fight the instinct to enter the water to assist the victim many well-meaning rescuers have died while trying to rescue humans and animals from electrically charged waters.
- should disconnect (switch OFF or unplug) all dock and shoreline electrical power as close as possible to the electrical power source.
- should, where applicable, disconnect the boat's shore power cord at the pedestal receptacle.
- should throw life ring or other flotation device to a conscious and able victim.
- should push the victim away from the presumed current source with an insulated pole.
- should call for help immediately Dial 911 or call on VHF Channel 16 as appropriate.
- should attempt first aid/CPR where the victim can be safely removed from the water.
- · must not throw a line to the victim and then pull the victim closer to the current source.
- · must not grab onto metal dock hardware while reaching for a nearby victim.

There is portable test equipment that will detect a hazardous electrical condition in the water in some cases. Typically, this equipment is not readily available, and its correct use requires special knowledge and training — Disconnecting the electrical power is always the recommended action.

Remember: An in-the-water shock hazard can exist, <u>or occur suddenly</u>, wherever shore-powered AC electrical equipment of any kind is located in the water, over the water, or near the water.

Additional resources including supporting information may be found at: www.electricshockdrowning.org; www.electricshockdrowningmn.com; www.qualitymarineservices.net; and www.boatus.com/seaworthy/ESD.asp.

Read purpose and disclaimer on reverse side of page.

Page 1 of 2

March 22, 2016







More Information





For Boaters, By Boaters™



Electric Shock Drowning



You are a safe, skillful boater.

You keep your vessel and its support equipment in tip-top operating condition.

You take all the required precautions against fire or explosion during and after refueling.

Despite all of this, you and your guests may not realize there may be another threat as you settle into another fun day on your boat while tied up in your transient or home slip.

The threat is electric shock drowning.

While your boat is in the slip, you may decide to jump off the swim platform to check out a prop that vibrated during the cruise, or recover a precious smart phone, sunglasses or tool. Any of those decisions could be a deadly mistake.















ELECTRIC SHOCK DROWNING PREVENTION ASSOCIATION

www.electricshockdrowning.org

Ed Lethert's MN ESDWeb Site www. electricshockdrowningmn.com

Electric Shock Drowning Prevention Association www.electricshockdrowning.org

Ed Lethert's MN ESD Web Site www.electricshockdrowningmn.com







Electric Shock Drowning Resource Center www.boatus.com/seaworthy/ESD.asp






"The Electric Shock Drowning of Samantha Chipley"




Article by Attorney B. Clark Batten II






ELECTRIC SHOCK DROWNING

The Truth Behind the Tragedies



10




















Electric Shock Drowning Prevention Association www.electricshockdrowning.org

Ed Lethert's MN ESD Web Site www.electricshockdrowningmn.com





